

Figure: 25 TAC §265.166(d)

Disinfectant Level	Minimum	Ideal	Maximum
Free Chlorine	1.0 ppm	2.0 – 3.0 ppm	8.0 ppm
Bromine	2.5 ppm	3.0 – 5.0 ppm	8.0 ppm
Combined Chlorine	None	None	None
pH	Not less than 7.0	7.2 – 7.6	7.8
Cyanuric Acid	None	10.0 – 30.0 ppm	50.0 ppm
ORP	600mV	650 – 750mV	900mV
Alkalinity	50 ppm		180 ppm
Calcium Hardness	150 ppm		1000 ppm
Algae	None	None	None